

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1070693

Product: Fuse-links for the protection of semiconductors devices

Type: P5...06gR,aR

Rating: 690 V AC, 400 V DC, 6-400 A

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 702743-01/01 of: 23.08.2007

A sample of the product was found to be in conformity with:
ČSN EN 60269-1:00 ed. 2+A1:05, ČSN EN 60269-4:99+A1:99+A2:03

The validity of the certificate is limited to: 31.8.2010

31.8.2007

Prague


Pavel Kudrna
Certification and Inspection Manager



Stamp



702743-01