

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1081021

Product: Circuit breaker

Type: BD40NE305-32-UA01, -40-UA01, -40-MTV9

Rating: $I_u=40$ A, $U_e=690$ V AC, 50/60 Hz

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 803934-01/01 of: 13.10.2008

A sample of the product was found to be in conformity with:
ČSN EN 60947-1:08 ed. 4, ČSN EN 60947-1:05+Z1:08 cl. 7.1.1.1,
ČSN EN 60947-2:04 ed. 2+Z1:04 cl. 5.2, 7.1.3, 8.3.3 - 8.3.6

The validity of the certificate is limited to: 30.11.2011

11.11.2008

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



803934-01