

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1090745

Product: Box-type assembly (steel-plastic)

Type: RZA 12N, RZA 24N, RZA 36N, RZA 48N

Rating: AC 400 V, 50 Hz, IP 30, IK 07

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 903184-01/01 of: 20.08.2009

A sample of the product was found to be in conformity with:

ČSN EN 60439-3:95+A1:97+A2:02,

ČSN EN 60439-1 ed. 2:00+A1:04+1:08 cl. 4, 5, 5.3, 8.2.2, 8.2.4.1b), 8.2.7, 8.2.9, 8.2.10, 8.2.11, 8.2.12, 8.2.13, 8.2.15,

ČSN 35 7030:72 cl. 70, 71, 73, 74, 75, 76, 78, 81,

ČSN EN 62208:04 cl. 6.2, 9.9, 9.10, 9.7, 8.6, 6.1, 9.2, 9.6, 9.8.1, 9.8.2, 9.8.3, 9.5, 9.3

The validity of the certificate is limited to: 31.8.2012

4.9.2009

Prague

Miroslav Sedláček
Certification and Inspection Manager



Stamp



903184-01